



Note 1: A 1/8-inch gap is required between sections of cleat.

Note 2: Each section of cover must overlap 1-1/2 inches.

Note 3: Each section of hook strip must overlap 1-1/2 inches.

Note 4: Stagger all seams by a minimum of 12 inches between cleat, hook strip and cover.

Note 5: This detail may also be used on parapet walls.

Note 6: If used in a gutter, back-seal membrane with an approved Duro-Last sealant and fasten 6 inches on center with approved Duro-Last fasteners. Refer to Detail Drawing 3050.

Note 7: Use roofing nails that penetrate substrate by a minimum of 1-1/2 inches.

Note 8: All field welds shall be a minimum of 1-1/2 inches wide.

Note 9: When wood nailers are required, the contractor is responsible for wood nailer type and installation procedures as per building code jurisdiction.

Note 10: Refer to specifications for vapor barrier, insulation and cover board requirements.

REVISED: 01/17/2022	METAL EDGE DETAIL FOR MECHANICALLY FASTENED SYSTEMS
PREVIOUS: N/A	T-EDGE ADVANCED
SCALE: NONE	NEW CONSTRUCTION OR RE-ROOF